

S. F. No. 1256—OS—(Rev. 4-71).

WATER WELL REPORT
STATE OF WASHINGTON3401-35J
Application No. 3401-35J
Permit No.(1) OWNER: Name Bob Craig Address 4033-184th Place S.W., Lynnwood, Wn. 98036(2) LOCATION OF WELL: County ISLAND NE 1/4 SE 1/4 Sec. 35 T32 N. R. 1 W.M.
Bearing and distance from section or subdivision corner see recorded S. P. 74-050 S30°W + 2180' N of S4 cor.(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☒
Irrigation ☐ Test Well ☐ Other ☐(4) TYPE OF WORK: Owner's number of well (if more than one) 1
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☒ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 30.1 ft. Depth of completed well 30.1 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6" Diam. from 0 ft. to 296' ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☐ " Diam. from ft. to ft.Perforations: Yes ☐ No ☒Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.Screens: Yes ☒ No ☐Manufacturer's Name COOK
Type WIRE Model No. DRASS
Diam. 6 Slot size 14 from 296 ft. to 301 ft.
Diam. Slot size from ft. to ft.Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.Surface seal: Yes ☒ No ☐ To what depth? 18+ ft.
Material used in seal CEMENT
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off (7) PUMP: Manufacturer's Name Sub
Type: H.P.(8) WATER LEVELS: Land-surface elevation 212+ ft.
above mean sea level. Static level 194 ft. below top of well Date 4-27-76
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☒ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.

" " " " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level
	<u>212+</u>		<u> </u>
	<u> </u>		<u> </u>

Date of test 4-27-76
Bailer test 20 gal./min. with 20 ft. drawdown after 2 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

(10) WELL LOG of Sec 35

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
GRAVELLY		20
GRAVELLY HARD PAN	20	50
SAND + GRAVEL	50	79
DIRTY SAND	79	146
SANDY CLAY	146	185
HARD PAN	185	192
DIRTY SAND	192	196
SANDY HARD PAN	196	236
SANDY CLAY	236	285
SOOPY SAND	285	290
WATER SAND	290	301
STILLIN SAND	301	+

Work started APR 1, 1976 Completed APR 20, 1976

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME WHIDBEY DRILLERS
(Person, firm, or corporation) (Type or print)Address OAK HARBOR W.N.[Signed] Dennis Fober
(Well Driller)License No. 0129 Date 4-27-76, 1976

(USE ADDITIONAL SHEETS IF NECESSARY)